

Ведомость учета тепловой энергии и теплоносителя в системе отопления

за период с 20.03.2024 по 18.04.2024

Потребитель: ООО "Паритет"
 Адрес объекта: ул. Подольская д. 107
 Теплосчетчик МКТС: № 010970-1 Версия МКТС: 2.51
 Формула расчета тепла: Q = M1(h1-h2)

Дата	Тепл.эн., Q, Гкал	Масса, т			Температура, °С			Давл., ати		Время, час		Отказы
		M1	M2	M1-M2	t1	t2	dt	P1	P2	работы	отказа	
20.03.24	1.531	195.13	193.91	1.19	50.6	42.8	7.9	5.2	5.0	23.99	0.01	He
21.03.24	1.610	195.69	194.50	1.17	51.8	43.6	8.2	5.0	4.8	23.99	0.01	He
22.03.24	1.683	195.81	194.66	1.16	53.0	44.4	8.6	4.9	4.7	23.98	0.02	He
23.03.24	1.530	200.69	199.47	1.24	51.2	43.6	7.6	4.9	4.7	23.99	0.01	He
24.03.24	1.314	200.44	199.19	1.25	47.7	41.1	6.6	4.9	4.7	23.99	0.01	He
25.03.24	1.333	196.63	195.41	1.19	47.7	41.0	6.8	4.9	4.7	23.99	0.01	He
26.03.24	1.311	194.13	192.94	1.20	47.5	40.8	6.8	4.9	4.7	23.99	0.01	He
27.03.24	1.280	193.75	192.53	1.22	46.8	40.1	6.6	5.0	4.8	23.90	0.10	HeDt
28.03.24	1.324	195.06	193.88	1.20	48.0	41.2	6.8	5.1	4.9	23.99	0.01	He
29.03.24	1.130	199.16	197.91	1.25	45.0	39.3	5.7	5.2	5.0	23.98	0.02	He
30.03.24	0.953	196.28	195.06	1.23	41.9	37.0	4.9	5.2	5.0	23.64	0.36	HeDt
31.03.24	0.939	199.69	198.41	1.27	41.8	37.0	4.7	5.2	5.0	23.74	0.26	HeDt
01.04.24	0.836	202.94	201.69	1.26	40.6	36.5	4.1	5.2	5.0	23.99	0.01	He
02.04.24	0.805	204.34	203.09	1.26	40.6	36.7	3.9	5.2	5.0	23.99	0.01	He
03.04.24	0.886	202.31	201.03	1.27	41.5	37.2	4.4	5.2	5.0	23.98	0.02	He
04.04.24	1.328	197.22	196.00	1.22	48.2	41.4	6.7	5.2	5.0	23.98	0.02	He
05.04.24	1.708	198.72	197.50	1.22	54.2	45.5	8.6	5.1	4.9	23.99	0.01	He
06.04.24	1.411	203.41	202.09	1.28	49.4	42.5	6.9	5.2	4.9	23.98	0.02	He
07.04.24	1.123	200.41	199.19	1.25	44.7	39.1	5.6	5.2	4.9	23.78	0.22	HeDt
08.04.24	0.878	201.31	200.06	1.25	40.9	36.5	4.4	5.2	4.9	23.98	0.02	He
09.04.24	0.787	200.88	199.66	1.22	40.6	36.7	3.9	5.2	4.9	23.51	0.49	ЭлHe
10.04.24	0.767	206.69	205.44	1.25	40.6	36.9	3.7	5.2	4.9	23.99	0.01	He
11.04.24	0.756	207.03	205.75	1.26	40.6	37.0	3.7	5.2	4.9	23.99	0.01	He
12.04.24	0.829	200.91	199.69	1.24	40.9	36.8	4.1	5.2	5.0	23.99	0.01	He
13.04.24	0.844	202.84	201.63	1.23	40.9	36.8	4.2	5.2	5.0	23.99	0.01	He
14.04.24	0.834	203.22	201.97	1.25	40.6	36.5	4.1	5.2	4.9	23.99	0.01	He
15.04.24	0.950	197.81	196.63	1.19	42.0	37.2	4.8	5.2	4.9	23.89	0.11	HeDt
16.04.24	0.947	199.28	198.03	1.22	42.2	37.5	4.8	5.2	4.9	23.59	0.41	HeDt
17.04.24	0.869	195.38	194.16	1.24	40.7	36.2	4.4	5.1	4.9	23.99	0.01	He
18.04.24	1.079	198.88	197.69	1.19	43.6	38.2	5.4	5.2	4.9	23.99	0.01	He
Итого:	33.576	5986.00	5949.13	36.86	44.8	39.2	5.6	5.1	4.9	717.76	2.24	ЭлHeDt

Показания МКТС (нарастающим итогом)

Дата	Q, Гкал	M1, т	M2, т	Траб, ч
18.04.24 24:00	3758.201	444757.69	444150.03	76677.48
19.03.24 24:00	3724.625	438771.69	438200.91	75959.72
Итого:	33.576	5986.00	5949.13	717.76

Отчетный период: 720.00 ч
 Время работы: 717.76 ч
 Суммарное время отказа: 2.24 ч = 0.47 + 0.39 + 0.00 + 0.00 + 1.38
Откл.эл-пит.(Эл) Неисправн.(He) Gv<min (DG) Gv>max(DG) dt<min (Dt)

Представитель
 потребителя: _____

Представитель
 поставщика: _____

Распечатано программой MktsPrint, версия: 1.36

Q = 33,681 Гкал

