

Ведомость учета тепловой энергии и теплоносителя в системе отопленияза период с 19.09.2023 по 18.10.2023 *по 22.10.23*Потребитель: ООО "Паритет"Адрес объекта: ул. Подольская д. 107Теплосчетчик МКТС: № 010970-1Версия МКТС: 2.51Формула расчета тепла: $Q = M1(h1-h2)$

Дата	Тепл.эн., Q, Гкал	Масса, т			Температура, °С			Давл., ати		Время, час		Отказы
		M1	M2	M1-M2	t1	t2	dt	P1	P2	работы	отказа	
19.09.23	0.000	0.00	0.00	0.00	23.5	21.9	1.5	-0.1	-0.0	23.99	0.01	He
20.09.23	0.000	0.00	0.00	0.00	23.9	22.7	1.2	-0.1	-0.0	23.98	0.02	He
21.09.23	0.000	0.00	0.00	0.00	24.2	22.9	1.3	-0.1	-0.0	23.98	0.02	He
22.09.23	0.000	0.00	0.00	0.00	24.4	23.2	1.2	-0.1	-0.0	23.98	0.02	He
23.09.23	0.000	0.00	0.00	0.00	24.4	23.1	1.3	-0.1	-0.0	23.98	0.02	He
24.09.23	0.000	0.00	0.00	0.00	24.4	23.2	1.3	-0.1	-0.0	23.98	0.02	He
25.09.23	0.000	0.00	0.00	0.00	24.3	22.9	1.4	-0.1	-0.0	23.98	0.02	He
26.09.23	0.000	0.00	0.00	0.00	24.1	22.4	1.7	-0.1	-0.0	23.98	0.02	He
27.09.23	0.000	0.00	0.00	0.00	23.9	22.5	1.4	-0.1	-0.0	23.98	0.02	He
28.09.23	0.000	0.00	0.00	0.00	23.6	22.3	1.3	-0.1	-0.0	23.98	0.02	He
29.09.23	0.000	0.00	0.00	0.00	23.7	22.4	1.3	-0.1	-0.0	23.98	0.02	He
30.09.23	0.000	0.00	0.00	0.00	23.8	22.5	1.3	-0.1	-0.0	23.98	0.02	He
01.10.23	0.000	0.00	0.00	0.00	23.7	22.3	1.4	-0.1	-0.0	23.99	0.01	He
02.10.23	0.000	0.00	0.00	0.00	22.9	21.3	1.7	-0.1	-0.0	23.98	0.02	He
03.10.23	0.000	0.00	0.00	0.00	22.6	20.9	1.6	-0.1	-0.0	23.98	0.02	He
04.10.23	0.000	0.00	0.00	0.00	22.8	21.5	1.3	-0.1	-0.0	23.99	0.01	He
05.10.23	0.000	0.00	0.00	0.00	22.5	20.9	1.6	-0.1	-0.0	23.98	0.02	He
06.10.23	0.000	0.00	0.00	0.00	21.5	19.9	1.6	-0.1	-0.0	23.98	0.02	He
07.10.23	0.411	95.81	95.31	0.48	41.1	36.8	4.3	1.4	1.3	23.96	0.04	HeDt
08.10.23	1.189	269.41	268.75	0.67	42.6	38.2	4.4	4.7	4.1	23.98	0.02	He
09.10.23	1.350	267.94	267.22	0.70	45.2	40.2	5.0	4.7	4.0	23.98	0.02	He
10.10.23	1.510	231.25	230.72	0.53	48.6	42.1	6.5	4.7	4.3	23.98	0.02	He
11.10.23	1.518	243.50	243.00	0.51	49.2	43.0	6.2	3.8	3.3	23.98	0.02	He
12.10.23	1.188	242.19	241.56	0.62	45.2	40.3	4.9	4.3	3.9	23.98	0.03	He
13.10.23	1.359	244.84	244.25	0.59	47.0	41.4	5.6	4.6	4.1	23.76	0.24	HeDt
14.10.23	1.552	252.41	251.78	0.62	51.4	45.3	6.2	4.7	4.2	23.99	0.01	He
15.10.23	1.308	251.50	250.84	0.68	47.8	42.6	5.2	4.7	4.2	23.99	0.01	He
16.10.23	1.682	247.06	246.34	0.70	53.3	46.5	6.8	4.6	4.2	23.99	0.01	He
17.10.23	2.112	243.19	242.47	0.74	59.3	50.6	8.7	4.6	4.2	23.98	0.02	He
18.10.23	1.945	237.28	236.56	0.72	57.3	49.1	8.2	4.5	4.1	23.99	0.01	He
Итого:	17.124	2826.38	2818.81	7.56	49.3	43.3	6.1	1.6	1.5	719.21	0.79	HeDt

Показания МКТС (нарастающим итогом)

Дата	Q, Гкал	M1, т	M2, т	Граб, ч
18.10.23 24:00	3376.049	407596.47	407211.53	72294.14
18.09.23 24:00	3358.925	404770.09	404392.72	71574.92
Итого:	17.124	2826.38	2818.81	719.21

Отчетный период: 720.00 чВремя работы: 719.21 чСуммарное время отказа: 0.79 ч

$$0.00 + 0.54 + 0.00 + 0.00 + 0.24$$

$$\text{Откл.эл-пит.(Эл)} \quad \text{Неисправн.(He)} \quad \text{Gv<min(ДГ)} \quad \text{Gv>max(ДГ)} \quad \text{dt<min(Dt)}$$
Представитель
потребителя: _____Представитель
поставщика: _____Распечатано программой MktsPrint, версия: 1.36*Q = 22,832 Ткач*