

ОТН

Ведомость учета тепловой энергии и теплоносителя для ГВС

за период с 18.10.2022 по 16.11.2022

Потребитель: ООО УК "Паритет"

Адрес объекта: ул. Подольская д.113

Теплосчетчик МКТС: № 013477-2

Версия МКТС: 2.54

Формула расчета тепла: $Q = M1(h1-h2)$

Дата	Тепл.эн., Q, Гкал	Масса, т			Температура, °С				Давл., атн		Время, час работы	отказа	
		M1	M2	M1-M2	t1	t2	dt	tхв	P1	P2			
18.10.22	---	---	---	---	---	---	---	---	---	---	---	24.00	Эл
19.10.22	---	---	---	---	---	---	---	---	---	---	---	24.00	Эл
20.10.22	---	---	---	---	---	---	---	---	---	---	---	24.00	Эл
21.10.22	---	---	---	---	---	---	---	---	---	---	---	24.00	Эл
22.10.22	---	---	---	---	---	---	---	---	---	---	---	24.00	Эл
23.10.22	---	---	---	---	---	---	---	---	---	---	---	24.00	Эл
24.10.22	0.950	141.38	141.13	0.25	47.9	41.1	6.8	---	-0.1	4.7	8.82	15.18	Эл
25.10.22	2.909	386.19	385.38	0.78	52.2	44.5	7.6	---	-0.1	4.7	24.00	0.00	
26.10.22	2.564	379.75	379.00	0.77	49.5	42.7	6.9	---	-0.1	4.7	24.00	0.00	
27.10.22	2.453	375.75	375.00	0.73	48.4	41.8	6.6	---	-0.1	4.7	24.00	0.00	
28.10.22	2.118	392.63	391.94	0.71	45.1	39.6	5.5	---	-0.1	4.7	24.00	0.00	
29.10.22	1.848	414.19	413.50	0.72	42.3	37.8	4.6	---	-0.1	4.7	24.00	0.00	
30.10.22	2.250	401.75	401.00	0.72	44.8	39.0	5.7	---	-0.1	4.7	24.00	0.00	
31.10.22	3.139	409.88	317.75	92.11	51.2	43.4	7.8	---	-0.1	4.4	24.00	0.00	
01.11.22	2.742	358.38	301.06	57.35	51.0	43.2	7.8	---	-0.1	4.6	24.00	0.00	
02.11.22	2.724	382.81	382.06	0.76	50.3	43.0	7.2	---	-0.1	4.8	24.00	0.00	
03.11.22	3.107	369.13	368.31	0.77	53.3	44.8	8.5	---	-0.1	4.7	24.00	0.00	
04.11.22	3.051	367.75	367.00	0.79	53.0	44.5	8.4	---	-0.1	4.7	24.00	0.00	
05.11.22	2.993	378.44	377.69	0.76	52.3	44.3	8.0	---	-0.1	4.7	24.00	0.00	
06.11.22	3.050	375.94	375.13	0.76	52.6	44.4	8.2	---	-0.1	4.7	24.00	0.00	
07.11.22	2.932	372.44	371.69	0.77	51.1	43.1	8.0	---	-0.1	4.7	24.00	0.00	
08.11.22	2.539	374.50	373.81	0.68	47.4	40.5	6.9	---	-0.1	4.7	24.00	0.00	
09.11.22	2.068	387.56	386.88	0.69	43.6	38.1	5.4	---	-0.1	4.7	24.00	0.00	
10.11.22	1.898	383.75	383.19	0.56	41.4	36.3	5.1	---	-0.1	4.7	24.00	0.00	
11.11.22	1.764	388.38	387.88	0.54	41.4	36.8	4.7	---	-0.1	4.8	24.00	0.00	
12.11.22	1.505	380.19	379.69	0.49	39.3	35.3	4.1	---	-0.1	4.8	24.00	0.00	
13.11.22	1.906	388.56	388.00	0.50	42.4	37.4	5.0	---	-0.1	4.7	24.00	0.00	
14.11.22	3.111	381.44	380.81	0.64	53.0	44.8	8.3	---	-0.1	4.8	24.00	0.00	
15.11.22	3.299	379.00	378.31	0.70	55.6	46.8	8.8	---	-0.1	4.7	24.00	0.00	
16.11.22	3.408	375.00	374.31	0.71	56.3	47.0	9.2	---	-0.1	4.7	24.00	0.00	
Итого:	60.328	8944.75	8780.50	164.26	48.5	41.6	6.9	---	-0.1	4.7	560.82	159.18	Эл

Показания МКТС (нарастающим итогом)

Дата	Q, Гкал	M1, т	M2, т	Траб, ч
16.11.22 24:00	4836.912	624686.44	622849.94	61455.97
17.10.22 24:00	4776.584	615741.69	614069.44	60895.15
Итого:	60.328	8944.75	8780.50	560.82

Отчетный период: 720.00 ч

Время работы: 560.82 ч

Суммарное время отказа: 159.18 ч = 159.18 + 0.00 + 0.00 + 0.00

Откл.эл-пит.(Эл) Неисправ.(Не) $Gv < \min(DG)$ $Gv > \max(DG)$ $dt < \min(Dt)$

Представитель
потребителя: _____

Представитель
поставщика: _____