

Ведомость учета тепловой энергии и теплоносителя в системе отопления

за период с 17.11.2022 по 11.12.2022

Потребитель: ООО УК "Паритет" 10/16.12.22

Адрес объекта: ул. Подольская д.113

Теплосчетчик МКТС: № 013477-2

Версия МКТС: 2.54

Формула расчета тепла: $Q = M1(h1-h2)$

Дата	Тепл.зн., Q, Гкал	Масса, т			Температура, °C			Давл., ати		Время, час		Отказы
		M1	M2	M1-M2	t1	t2	dt	P1	P2	работы	отказа	
17.11.22	3.951	372.25	371.38	0.81	60.8	50.1	10.7	-0.1	4.7	24.00	0.00	
18.11.22	3.978	365.56	364.69	0.94	61.1	50.2	11.0	-0.1	4.7	24.00	0.00	
19.11.22	4.002	375.50	374.13	1.36	61.3	50.6	10.8	-0.1	4.7	24.00	0.00	
20.11.22	3.555	370.63	369.81	0.83	57.3	47.6	9.7	-0.1	4.8	24.00	0.00	
21.11.22	3.813	367.88	367.06	0.80	59.1	48.7	10.5	-0.1	4.8	24.00	0.00	
22.11.22	3.235	364.63	363.94	0.74	53.6	44.7	9.0	-0.1	4.8	24.00	0.00	
23.11.22	3.209	365.50	364.81	0.66	51.8	42.9	8.9	-0.1	4.8	24.00	0.00	
24.11.22	2.563	249.31	249.06	0.24	55.1	44.7	10.4	-0.1	3.5	23.63	0.37	Дт
25.11.22	4.127	383.06	382.19	0.85	61.4	50.5	10.9	-0.1	4.7	24.00	0.00	
26.11.22	3.863	384.44	383.69	0.78	59.6	49.5	10.2	-0.1	4.8	24.00	0.00	
27.11.22	3.719	385.13	384.38	0.76	58.5	48.8	9.8	-0.1	4.8	24.00	0.00	
28.11.22	3.742	376.00	375.19	0.75	58.6	48.5	10.1	-0.1	4.8	24.00	0.00	
29.11.22	4.111	375.69	374.94	0.78	61.5	50.4	11.0	-0.1	4.8	24.00	0.00	
30.11.22	4.561	373.38	372.56	0.81	65.5	53.1	12.3	-0.0	4.8	24.00	0.00	
01.12.22	4.602	364.19	363.38	0.80	65.9	53.2	12.7	-0.0	4.8	24.00	0.00	
02.12.22	4.472	367.06	366.25	0.82	64.9	52.6	12.3	-0.1	4.8	24.00	0.00	
03.12.22	4.525	373.50	372.75	0.75	64.8	52.6	12.2	-0.1	4.8	24.00	0.00	
04.12.22	4.946	382.13	381.38	0.77	67.9	54.8	13.0	-0.0	4.8	24.00	0.00	
05.12.22	4.921	370.81	370.13	0.70	68.3	55.0	13.4	-0.0	4.8	24.00	0.00	
06.12.22	---	---	---	---	---	---	---	---	---	---	---	НД
07.12.22	---	---	---	---	---	---	---	---	---	---	---	НД
08.12.22	---	---	---	---	---	---	---	---	---	---	---	НД
09.12.22	---	---	---	---	---	---	---	---	---	---	---	НД
10.12.22	---	---	---	---	---	---	---	---	---	---	---	НД
11.12.22	---	---	---	---	---	---	---	---	---	---	---	НД
Итого:	75.896	6966.63	6951.69	14.95	61.0	50.0	11.0	-0.1	4.7	455.63	0.37	НД

Показания МКТС (нарастающим итогом)

Дата	Q, Гкал	M1, т	M2, т	Траб, ч
11.12.22 24:00	4912.808	631653.06	629801.63	61911.60
16.11.22 24:00	4836.912	624686.44	622849.94	61455.97
Итого:	75.896	6966.63	6951.69	455.63

Отчетный период: 600.00 ч

Время работы: 455.63 ч

Суммарное время отказа: 0.37 ч = 0.00 + 0.00 + 0.00 + 0.00 + 0.37

Откл.эл-пит.(Эл) Неисправн.(Не) Gv<min(ДГ) Gv>max(ДГ) dt<min(Дт)

Представитель
потребителя:

Представитель
поставщика:

Распечатано программой MktsPrint, версия: 1.31



Q_{от} = 119,933 Гкал