

**Ведомость учета тепловой энергии и теплоносителя в системе отопления**за период с 16.10.2024 по 15.11.2024Потребитель: ООО "Паритет"Адрес объекта: Пушино микрорайон АБ д. 12Теплосчетчик МКТС: № 050046-1Версия МКТС: 6.67Формула расчета тепла:  $Q = M1(h1-h2)$ 

Дата	Тепл.эн., Q, Гкал	Масса, т			Температура, °С			Давл., ати		Время, час		Отказы
		M1	M2	M1-M2	t1	t2	dt	P1	P2	работы	отказа	
16.10.24	4.502	301.13	298.81	2.29	66.0	51.1	15.0	4.6	3.7	22.89	1.11	He
17.10.24	4.777	325.06	322.69	2.39	66.5	51.8	14.7	4.6	3.7	23.36	0.64	He
18.10.24	4.906	343.94	341.47	2.49	66.0	51.7	14.3	4.6	3.7	24.00	0.00	
19.10.24	4.622	305.25	302.91	2.33	66.2	51.1	15.1	4.6	3.7	23.22	0.78	He
20.10.24	4.532	303.13	300.84	2.28	66.2	51.3	14.9	4.6	3.7	22.71	1.29	He
21.10.24	4.019	266.00	263.97	2.04	66.5	51.4	15.1	4.6	3.7	21.09	2.91	He
22.10.24	4.365	298.56	296.31	2.25	66.4	51.8	14.6	4.7	3.7	24.00	0.00	
23.10.24	4.285	295.91	293.72	2.18	66.1	51.6	14.5	4.7	3.7	23.43	0.57	He
24.10.24	4.542	322.72	320.44	2.28	65.8	51.7	14.1	4.6	3.7	23.85	0.15	ЭлHe
25.10.24	4.323	298.34	296.19	2.18	66.3	51.8	14.5	4.7	3.7	23.60	0.40	He
26.10.24	4.661	334.59	332.25	2.32	66.3	52.3	13.9	4.7	3.7	23.59	0.41	He
27.10.24	4.353	294.69	292.47	2.20	66.2	51.5	14.8	4.7	3.7	23.72	0.28	He
28.10.24	4.269	285.97	283.81	2.16	66.2	51.3	14.9	4.7	3.7	24.00	0.00	
29.10.24	4.322	295.75	293.59	2.17	66.0	51.4	14.6	4.7	3.7	23.79	0.21	He
30.10.24	4.655	340.28	337.94	2.32	65.9	52.2	13.7	4.6	3.7	23.65	0.35	He
31.10.24	4.595	325.88	323.63	2.27	65.5	51.4	14.1	4.6	3.7	23.79	0.21	He
01.11.24	4.698	348.91	346.59	2.31	65.2	51.8	13.5	4.7	3.7	24.00	0.00	
02.11.24	4.954	346.03	343.59	2.43	67.2	52.9	14.3	4.7	3.7	23.65	0.35	He
03.11.24	5.218	370.66	368.16	2.51	66.8	52.7	14.1	4.6	3.7	23.71	0.29	He
04.11.24	5.315	375.28	372.63	2.64	66.9	52.8	14.2	4.7	3.7	23.84	0.16	He
05.11.24	5.463	379.34	376.50	2.87	67.5	53.1	14.4	4.7	3.7	24.00	0.00	
06.11.24	5.500	374.53	371.69	2.82	68.2	53.5	14.7	4.7	3.7	23.74	0.26	He
07.11.24	4.838	303.44	300.97	2.48	68.0	52.1	15.9	4.7	3.7	23.05	0.95	He
08.11.24	4.880	300.94	298.44	2.49	68.3	52.2	16.2	4.8	3.7	23.41	0.59	He
09.11.24	5.165	317.78	315.22	2.57	68.4	52.2	16.2	4.7	3.7	24.00	0.00	
10.11.24	5.163	313.88	311.31	2.56	68.6	52.1	16.4	4.8	3.7	23.72	0.28	He
11.11.24	5.237	360.31	357.72	2.59	67.7	53.1	14.5	4.7	3.7	22.61	1.39	He
12.11.24	5.488	377.16	374.47	2.72	68.3	53.8	14.5	4.7	3.7	23.60	0.40	He
13.11.24	5.488	382.56	379.84	2.70	67.7	53.3	14.3	4.7	3.7	24.00	0.00	
14.11.24	5.401	374.72	372.09	2.62	67.5	53.1	14.4	4.7	3.7	23.54	0.46	He
15.11.24	5.223	365.41	362.88	2.51	67.4	53.2	14.3	4.7	3.7	22.97	1.03	He
<b>Итого:</b>	<b>149.758</b>	<b>10228.13</b>	<b>10153.13</b>	<b>74.98</b>	<b>66.9</b>	<b>52.2</b>	<b>14.6</b>	<b>4.7</b>	<b>3.7</b>	<b>728.55</b>	<b>15.45</b>	<b>ЭлHe</b>

**Показания МКТС (нарастающим итогом)**

Дата	Q, Гкал	M1, т	M2, т	Траб, ч
15.11.24 24:00	5405.870	372662.16	369139.81	35619.68
15.10.24 24:00	5256.111	362434.03	358986.69	34891.12
<b>Итого:</b>	<b>149.758</b>	<b>10228.13</b>	<b>10153.13</b>	<b>728.55</b>

Отчетный период: 744.00 чВремя работы: 728.55 чСуммарное время отказа: 15.45 ч = 0.00 + 15.44 + 0.00 + 0.00 + 0.00

Откл.эл.-пит.(Эл) Неисправн.(He) Gv&lt;min (DG) Gv&gt;max(DG) dt&lt;min (Dt)

Представитель  
потребителя:Представитель  
поставщика:Распечатано программой MktsPrint, версия: 1.36