

Ведомость учета тепловой энергии и теплоносителя для РВС

за период с 17.12.2022 по 16.01.2023

Потребитель: ООО УК "Паритет" *ОТН*
 Адрес объекта: ул. Подольская д.113
 Теплосчетчик МКТС: № 013477-2 Версия МКТС: 2.54
 Формула расчета тепла: $Q = M1(h1-h2)$

Дата	Тепл.эн., Q, Гкал	Масса, т			Температура, °С				Давл., атм		Время, час		Отказы
		M1	M2	M1-M2	t1	t2	dt	tхв	P1	P2	работы	отказа	
17.12.22	3.780	365.63	365.00	0.60	58.4	48.0	10.5	---	-0.1	4.8	24.00	0.00	
18.12.22	4.361	364.38	363.81	0.59	60.5	48.4	12.1	---	-0.1	4.8	24.00	0.00	
19.12.22	4.811	358.06	357.38	0.69	63.7	50.2	13.5	---	-0.0	4.8	24.00	0.00	
20.12.22	4.640	366.31	365.63	0.65	64.7	51.9	12.8	---	-0.0	4.8	24.00	0.00	
21.12.22	3.740	360.31	359.75	0.55	58.9	48.4	10.5	---	-0.1	4.9	24.00	0.00	
22.12.22	3.024	357.63	357.19	0.46	52.7	44.1	8.6	---	-0.1	4.8	24.00	0.00	
23.12.22	2.934	356.63	356.13	0.47	51.6	43.3	8.3	---	-0.1	4.8	24.00	0.00	
24.12.22	3.126	366.94	366.44	0.53	52.0	43.4	8.6	---	-0.1	4.8	24.00	0.00	
25.12.22	3.883	365.38	364.75	0.60	58.0	47.3	10.7	---	-0.1	4.8	24.00	0.00	
26.12.22	4.060	358.56	357.94	0.66	61.2	49.7	11.4	---	-0.1	4.8	24.00	0.00	
27.12.22	3.620	352.25	351.63	0.58	58.2	47.8	10.4	---	-0.1	4.8	24.00	0.00	
28.12.22	3.294	351.63	351.13	0.55	54.7	45.2	9.5	---	-0.1	4.8	24.00	0.00	
29.12.22	3.382	352.06	351.50	0.55	54.8	45.1	9.7	---	-0.1	4.8	24.00	0.00	
30.12.22	3.047	354.44	353.94	0.51	53.1	44.4	8.7	---	-0.1	4.8	24.00	0.00	
31.12.22	2.787	336.06	335.56	0.50	51.3	42.9	8.4	---	-0.1	4.7	23.91	0.09	Dt
01.01.23	2.832	365.88	365.31	0.56	49.9	42.0	7.9	---	-0.1	4.8	24.00	0.00	
02.01.23	3.508	358.63	358.06	0.59	52.3	42.3	9.9	---	-0.1	4.8	24.00	0.00	
03.01.23	3.279	360.75	360.13	0.61	53.3	44.1	9.2	---	-0.1	4.8	24.00	0.00	
04.01.23	3.756	354.56	354.00	0.58	56.2	45.5	10.7	---	-0.1	4.8	24.00	0.00	
05.01.23	4.491	358.19	357.50	0.69	60.5	47.8	12.6	---	-0.1	4.8	24.00	0.00	
06.01.23	5.919	347.44	346.63	0.79	72.2	55.1	17.1	---	-0.0	4.8	24.00	0.00	
07.01.23	5.504	345.31	344.56	0.70	71.5	55.4	16.0	---	-0.0	4.8	24.00	0.00	
08.01.23	5.576	347.94	347.38	0.62	72.1	56.0	16.1	---	-0.0	4.8	24.00	0.00	
09.01.23	5.611	346.06	345.50	0.56	72.3	56.0	16.3	---	-0.0	4.8	24.00	0.00	
10.01.23	5.547	353.44	352.94	0.51	71.6	55.8	15.8	---	-0.0	4.8	24.00	0.00	
11.01.23	4.217	356.94	356.44	0.46	60.2	48.3	11.9	---	-0.0	4.8	24.00	0.00	
12.01.23	4.859	362.81	362.38	0.48	66.4	52.9	13.5	---	-0.0	4.8	24.00	0.00	
13.01.23	4.192	360.81	360.38	0.40	61.4	49.7	11.7	---	-0.1	4.8	24.00	0.00	
14.01.23	3.722	364.38	364.00	0.35	57.7	47.4	10.3	---	-0.1	4.9	24.00	0.00	
15.01.23	3.771	368.00	367.63	0.38	58.1	47.8	10.4	---	-0.1	4.9	24.00	0.00	
16.01.23	4.034	360.81	360.44	0.41	60.3	49.0	11.3	---	-0.1	4.9	24.00	0.00	
Итого:	125.307	11078.19	11061.00	17.17	59.6	48.2	11.4	---	-0.1	4.8	743.91	0.09	Dt

Показания МКТС (нарастающим итогом)

Дата	Q, Гкал	M1, т	M2, т	Траб, ч
16.01.23 24:00	5082.697	646747.19	644872.75	62919.51
16.12.22 24:00	4957.390	635669.00	633811.75	62175.60
Итого:	125.307	11078.19	11061.00	743.91

Отчетный период: 744.00 ч

Время работы: 743.91 ч

Суммарное время отказа: 0.09 ч = $\frac{0.00}{\text{Откл.эл-пит.(Эл)}} + \frac{0.00}{\text{Неисправн.(Не)}} + \frac{0.00}{\text{Gv<min(DG)}} + \frac{0.00}{\text{Gv>max(DG)}} + \frac{0.09}{\text{dt<min(Dt)}}$

Представитель
потребителя:Представитель
поставщика: