

Глоб.: 0.06 - 60.0 м3/ч Ду= мм
 Собр.: 0.06 - 60.0 м3/ч Ду= мм
 Гп : 10 л/Имп

посуточная ведомость учета параметров теплопотребления
 с 17.12.2022 по 16.01.2023

Дата	Q Гкал	Масса, тонн. Объем, м3				Температура, °С				Давление		Время, час		Классиф ошибок	
		M1	V1	M2	V2	M1-M2 разбор	t1	t2	t1-t2	tхв	P1 атм	P2 атм	ТН		Работы ТР
17.12.22	5.341	497.44	508.6563	501.05	509.3203	-3.61	70.3	59.6	10.7	0.0	5.5	4.2	0.00	24.00	
18.12.22	5.309	491.27	502.2422	494.80	502.9375	-3.54	70.2	59.4	10.8	0.0	5.5	4.2	0.00	24.00	
19.12.22	5.487	480.44	491.4141	483.89	491.8750	-3.45	71.0	59.6	11.4	0.0	5.4	4.2	0.00	24.00	
20.12.22	5.434	482.88	493.7500	486.30	494.2734	-3.43	70.5	59.2	11.2	0.0	5.4	4.2	0.00	24.00	
21.12.22	5.470	514.45	526.1641	518.19	526.9141	-3.73	70.8	60.2	10.6	0.0	5.6	4.2	0.00	24.00	
22.12.22	5.431	509.63	521.3203	513.37	522.1172	-3.73	71.1	60.5	10.6	0.0	5.5	4.1	0.00	24.00	
23.12.22	5.324	511.78	523.4453	515.56	524.2813	-3.78	70.8	60.4	10.4	0.0	5.6	4.1	0.00	24.00	
24.12.22	5.231	514.98	526.6094	518.75	527.5703	-3.77	70.6	60.5	10.1	0.0	5.6	4.1	0.00	24.00	
25.12.22	5.329	499.45	510.9141	503.16	511.7109	-3.72	71.1	60.4	10.6	0.0	5.5	4.1	0.00	24.00	
26.12.22	5.315	493.91	505.1406	497.52	505.8594	-3.61	70.7	60.0	10.7	0.0	5.5	4.1	0.00	24.00	
27.12.22	5.391	495.09	506.2969	498.69	506.9844	-3.59	70.6	59.8	10.9	0.0	5.5	4.2	0.00	24.00	
28.12.22	5.368	505.49	517.0547	509.29	517.8828	-3.80	70.9	60.3	10.6	0.0	5.5	4.1	0.00	24.00	
29.12.22	5.297	503.71	515.0703	507.44	515.9609	-3.73	70.5	60.1	10.5	0.0	5.5	4.1	0.00	24.00	
30.12.22	5.325	513.74	525.3984	517.59	526.3906	-3.84	70.7	60.4	10.3	0.0	5.6	4.1	0.00	24.00	
31.12.22	5.276	516.80	528.4922	520.67	529.5469	-3.87	70.6	60.4	10.2	0.0	5.6	4.1	0.00	24.00	
01.01.23	5.308	532.63	544.7158	536.57	545.7798	-3.94	70.7	60.8	9.9	0.0	5.7	4.1	0.00	24.00	
02.01.23	5.148	525.40	537.0452	529.40	538.2803	-4.00	69.8	60.0	9.8	0.0	5.7	4.1	0.00	24.00	
03.01.23	5.282	527.23	539.1107	531.16	540.1895	-3.93	70.4	60.4	10.0	0.0	5.7	4.2	0.00	24.00	
04.01.23	5.295	515.33	526.8651	519.14	527.8374	-3.81	70.2	60.1	10.1	0.0	5.6	4.2	0.00	24.00	
05.01.23	5.295	509.93	521.4077	513.68	522.3040	-3.76	70.4	60.0	10.4	0.0	5.6	4.2	0.00	24.00	
06.01.23	6.077	490.95	505.2383	494.49	504.5532	-3.54	80.7	66.6	14.2	0.0	5.5	4.2	0.00	24.00	
07.01.23	7.821	495.68	511.6367	499.28	510.3235	-3.60	85.3	69.6	15.7	0.0	5.5	4.2	0.00	24.00	
08.01.23	6.623	500.26	515.8896	503.84	514.7327	-3.58	83.9	68.7	15.2	0.0	5.5	4.2	0.00	24.00	
09.01.23	7.513	508.33	523.7925	511.94	522.8027	-3.62	82.8	68.0	14.7	0.0	5.6	4.2	0.00	24.00	
10.01.23	6.760	503.84	517.5068	507.35	517.0654	-3.52	77.7	64.4	13.4	0.0	5.5	4.2	0.00	24.00	
11.01.23	6.284	490.15	502.3970	493.53	502.2324	-3.38	74.4	61.6	12.8	0.0	5.4	4.2	0.00	24.00	
12.01.23	5.865	474.38	485.5757	477.69	485.6484	-3.40	72.2	59.8	12.3	0.0	5.4	4.2	0.00	24.00	
13.01.23	5.790	486.95	498.3862	490.36	498.6206	-3.42	72.0	60.1	11.9	0.0	5.4	4.2	0.00	24.00	
14.01.23	5.688	503.87	515.6479	507.46	516.1187	-3.59	71.8	60.6	11.3	0.0	5.6	4.2	0.00	24.00	
15.01.23	5.632	507.70	519.5337	511.39	520.1479	-3.68	71.8	60.7	11.1	0.0	5.6	4.2	0.00	24.00	
16.01.23	5.584	498.55	510.1577	502.13	510.6763	-3.58	71.7	60.5	11.2	0.0	5.5	4.2	0.00	24.00	
Итого	178.129	15602.2	15976.8955	15715.6	15990.9678	-113.45	72.8	61.4	11.4	0.0	5.5	4.2	0.00	744.00	0.00

период	млн руб.	млн руб.	млн руб.	млн руб.	млн руб.	млн руб.	млн руб.
период t2-t1 < min	(u)	(d)	(g)	VI	V2	TP	TP
01.01.23 24:00	97.802	8071.17	8129.40	8274.93	8277.34	384.00	384.00
01.01.23 00:00	0.000	0.00	0.00	0.00	0.00	0.00	0.00
31.12.22 24:00	1153.153	111705.05	112368.10	118172.45	118205.21	6011.43	6011.43
17.12.22 00:00	1072.826	104173.99	104781.83	110470.48	110491.59	5651.43	5651.43
Итого	178.129	15602.23	15715.68	15976.90	15990.97	744.00	744.00

период — 744.00_час. период норм. работы — 744.00_час.

период отключения питания (u) — 0.000_час. период функц.отказа (E) — 0.000_час.
 период t2-t1 < min (d) — 0.000_час. период G<min (g) — 0.000_час.
 период G>max (g) — 0.000_час.

представитель абонента _____ представитель теплоснабжающей организации _____

