

Ведомость учета тепловой энергии и теплоносителя для ГВС

за период с 10.12.2021 по 17.01.2022

Потребитель:

ООО УК Партией

Адрес объекта:

ул. Подольской 107

Теплосчетчик МКТС: № 010970-2

Версия МКТС: 2.51

Формула расчета тепла: $Q = M1(h1-hx) - M2(h2-hx)$

Дата	Тепл.эн., Q, Гкал	Масса, т			Температура, °C				Давл., ати		Время, час		Отказы
		M1	M2	M1-M2	t1	t2	dt	txв	P1	P2	работы	отказа	
10.12.21	0.643	57.70	53.06	4.63	64.7	57.4	7.3	10.0	5.5	4.7	24.00	0.00	
11.12.21	0.729	57.55	51.41	6.13	65.4	57.9	7.5	10.0	5.5	4.7	24.00	0.00	
12.12.21	0.726	58.30	52.95	5.36	67.6	59.7	7.9	10.0	5.5	4.7	24.00	0.00	
13.12.21	0.698	61.00	55.73	5.27	65.8	58.6	7.2	10.0	5.5	4.5	24.00	0.00	
14.12.21	0.631	59.47	55.08	4.37	64.5	57.4	7.1	10.0	5.5	4.6	24.00	0.00	
15.12.21	0.666	60.48	55.41	5.09	64.8	57.8	7.0	10.0	5.5	4.5	24.00	0.00	
16.12.21	0.552	60.23	57.14	3.11	62.9	56.2	6.8	10.0	5.5	4.5	24.00	0.00	Dt
17.12.21	0.634	61.44	56.80	4.63	63.7	57.0	6.8	10.0	5.5	4.5	24.00	0.00	
18.12.21	0.723	62.98	56.80	6.19	64.4	57.6	6.8	10.0	5.5	4.4	24.00	0.00	
19.12.21	0.694	61.88	55.86	6.02	63.6	57.0	6.6	10.0	5.5	4.5	24.00	0.00	
20.12.21	0.527	59.86	57.23	2.63	63.0	56.3	6.8	10.0	5.5	4.6	24.00	0.00	
21.12.21	0.620	61.72	57.33	4.39	63.5	56.8	6.7	10.0	5.5	4.5	24.00	0.00	Dt
22.12.21	0.622	61.30	56.92	4.37	63.5	56.7	6.8	10.0	5.5	4.5	23.99	0.01	Dt
23.12.21	0.630	60.42	56.36	4.06	64.5	57.3	7.2	10.0	5.5	4.5	24.00	0.00	Dt
24.12.21	0.654	60.11	55.58	4.54	64.5	57.2	7.3	10.0	5.5	4.5	23.99	0.01	Dt
25.12.21	0.680	58.88	53.50	5.38	64.1	56.8	7.3	10.0	5.5	4.6	23.99	0.01	Dt
26.12.21	0.693	60.47	54.98	5.48	64.7	57.5	7.2	10.0	5.5	4.5	23.99	0.01	Dt
27.12.21	0.656	60.36	55.48	4.86	64.3	57.2	7.1	10.0	5.5	4.5	23.99	0.01	Dt
28.12.21	0.547	59.13	56.09	3.04	63.2	56.3	6.9	10.0	5.5	4.5	23.98	0.02	Dt
29.12.21	0.697	60.55	54.80	5.75	64.8	57.8	7.0	10.0	5.5	4.5	23.99	0.01	Dt
30.12.21	0.637	59.94	55.42	4.52	64.5	57.5	7.0	10.0	5.5	4.6	23.98	0.01	Dt
31.12.21	0.794	61.25	52.83	8.42	63.1	56.6	6.6	10.0	5.5	4.5	23.96	0.04	Dt
01.01.22	0.505	61.47	59.44	2.02	63.9	57.3	6.7	10.0	5.4	4.4	23.97	0.03	Dt
02.01.22	0.603	61.55	58.06	3.48	65.6	58.5	7.1	10.0	5.4	4.4	23.99	0.01	Dt
03.01.22	0.562	60.64	57.58	3.07	64.3	57.4	6.8	10.0	5.5	4.5	23.96	0.04	Dt
04.01.22	0.605	60.94	56.98	3.96	64.2	57.4	6.8	10.0	5.5	4.5	23.98	0.01	Dt
05.01.22	0.533	60.31	57.88	2.42	64.6	57.7	6.9	10.0	5.5	4.5	23.95	0.05	Dt
06.01.22	0.567	58.77	55.63	3.14	65.1	58.0	7.1	10.0	5.5	4.5	23.95	0.05	Dt
07.01.22	0.592	55.11	51.08	4.04	63.9	56.5	7.3	10.0	5.5	4.8	23.93	0.07	Dt
08.01.22	0.637	55.31	50.31	4.99	63.8	56.4	7.3	10.0	5.5	4.7	23.91	0.09	Dt
09.01.22	0.590	54.67	50.73	3.95	63.8	56.4	7.4	10.0	5.5	4.7	23.88	0.12	Dt
10.01.22	0.579	55.38	51.78	3.60	64.5	57.1	7.4	10.0	5.5	4.7	23.88	0.12	Dt
11.01.22	0.563	55.14	51.81	3.32	64.1	56.8	7.4	10.0	5.5	4.7	23.88	0.12	Dt
12.01.22	0.550	53.75	50.09	3.66	62.5	55.4	7.1	10.0	5.5	4.8	23.71	0.29	Dt
13.01.22	0.533	56.34	53.70	2.63	64.0	56.7	7.3	10.0	5.5	4.6	23.86	0.14	Dt
14.01.22	0.603	59.58	55.13	4.45	63.5	56.9	6.6	10.0	5.5	4.5	23.59	0.41	Dt
15.01.22	0.547	59.59	56.53	3.06	64.0	57.2	6.7	10.0	5.5	4.5	23.75	0.25	Dt
16.01.22	0.622	59.97	55.16	4.81	63.7	57.1	6.6	10.0	5.5	4.5	23.74	0.26	Dt
17.01.22	0.482	57.88	55.98	1.89	63.8	57.0	6.8	10.0	5.5	4.5	23.52	0.48	Dt
Итого:	24.123	2311.39	2144.64	166.73	64.2	57.2	7.0	10.0	5.5	4.6	933.32	2.68	Dt

Показания МКТС (нарастающим итогом)

Дата	Q, Гкал	M1, т	M2, т	Траб, ч
17.01.22 24:00	2109.538	199528.80	177609.58	61843.20
09.12.21 24:00	2085.416	197217.41	175464.94	60909.89
Итого:	24.123	2311.39	2144.64	933.32

Отчетный период: 936.00 чВремя работы: 933.32 чСуммарное время отказа: 2.68 ч

0.00

+ 0.00

+ 0.00

+ 0.00

+ 0.00

+ 2.68

Откл.эл-пит.(Эл)

Неисправн.(Не)

Gv<min (DG)

Gv>max(DG)

dt<min (Dt)

Представитель

Представитель